

Department of Industrial Relations
Division of Occupational Safety and Health
ELEVATOR UNIT HQS
6980 Santa Teresa Boulevard, Suite 130
San Jose, CA 95119
Phone: 408.362.2120
Fax: 408.362.2131



December 29, 2009

CIRCULAR LETTER E-09-01

**TO: Installers, Manufacturers of Conveyances and Related Equipment and,
Other Interested Parties**

**SUBJECT: Governor Overspeed Switch to be used as an Ascending Car Overspeed
Protection Device per Section 3141 [ASME A17.1-2004], Section
2.26.2.29**

**The Division of Occupational Safety and Health's Elevator Unit will allow the use
of another device specified in Section 3141[ASME A17.1-2004], Section 2.26.2 as a
detection means for ascending car overspeed protection device provided the
device complies with Section 2.19.1.1.2(a).**

**If you have any questions pertaining to this regulation, please contact the
Elevator Unit Headquarters at 408-362-2120.**

**Debra Tudor
Acting Principal Engineer
DOSH-Elevator Unit HQS**

DT:pp